
2 INCH MONITORING STATIONS

- Terminals on the outside of the lid provide fast, convenient test checks.
- Available with pre-wiring to outside terminals in the lid. One red and one black 15' coil of plastic coated, #12 AWG type THW, 600 volt, oil resistant solid copper wire is contained in the station.
- Wires easily uncoil to reach connection points.
- Stations with terminals but no wires is available.
- The 15" plastic box has a 23/8" I.D. and is available in either straight or flanged top for installation at grade level.
- Made from SUPERIOR GRADE ABS plastic. It's long lasting and won't rust, rot or corrode.
- Adjustable to grade test stations are available upon request.



- Cast iron lids are marked "Test 1 2".
- You may order custom lids for an additional charge.
- A permanent "Real" magnet is in every box for easy location with electronic locater.
- Monitor lids available in marker posts. See marker post spec sheet to order.
- Underground installation protects the station from vandalism and is esthetically superior. However, above ground monitor stations are also available.



HOW TO ORDER SUPERIOR GRADE 2" MONITORING STATIONS

Choose from the following categories to build the monitoring station best suited to your personal needs.

ALL monitoring stations begin with **M2**.... continue to build your model number from the following categories:

M2

F = Plastic Flange Top S = Straight Top Flange N = Not Wired W = Wired Group One, Code F)	ONE = UPPER TUBE STYLE F = Plastic Flange Top S = Straight Top Flange	TWO = WIRE N = Not Wired W = Wired	THREE = LID COLOR (Black is Standard) A = Yellow	FOUR = VENT HOLE L = One 3/8" Vent Hole (Mandatory for Group One, Code F)
---	--	------------------------------------	--	---

FIVE = ARCHES AND TELESCOPING BOX

(A 15" Straight Tube, Flared at the Bottom is Standard)

Q = Telescoping Box, $18\frac{5}{8}$ " - 24", Without an Arch, Flared

R = Telescoping Box, $18\frac{5}{8}$ " - 24", With an Arch

FOR OTHER OPTIONS OR VARIATIONS, PLEASE CONSULT THE FACTORY.

